



-Aggregate base or approved equal

SECTION A-A

SECTION B-B

NOTES:

- Score lines shall be 1/4 inch deep and 48 inches apart in sidewalk areas.
- 2. PCC shall be 'Class A' or an approved 3000 psi mix with a light broom finish.
- Welded wire fabric shall be used when driveway serves more than one residential units.
- Driveway locations shall be approved by the City Engineer.
- 5. The minimum spacing between driveways serving the same parcel shall be 18 feet.
- Limits of Driveway widths shall be as shown unless otherwise approved by the City Engineer.

Access to developed site shall be maintained.

REV	DATE APPROVE	D DESIGN			CONTRACT CONTRACTOR
		DRAWN	CITY OF MILPITAS PUBLIC WORKS DEPARTMENT ENGINEERING DIVISION STANDARD DRAWING	RESIDENTIAL DRIVEWAY	NO. 430
		CHECKED			277
		APPROVED BY			ADOPTED
		Vacad MAChery			C= 2560
		CITY ENGINEER			DATE: 1-21-7
		DATE 19/8			SHEET OF